



*ESTIMATED SOIL PROPERTIES\**

SOIL UNIT	RANGE (%)	DEPTH TO BEDROCK (IN)	DEPTH TO WATER TABLE INDICATORS (IN)	RECOMMEND. TRENCH DEPTH (IN)	SUITABILITY CODES	ESTIMATED PERC. RATE AT DIFFERENT DEPTHS	
						DEPTH (IN)	PERC RATE (MIN/IN)
FILL OVER CUT	0-25%	>72	>72	48	A	40-60	45
PACOLET	0-25%	>72	>72	36	A	24-60	45
STARR	0-25%	---	---	N/A	D	N/A	N/A

\* All depth references are with respect to the original grade at the time of this inspection.  
 \*\* Fill areas are considered unsuitable for septic system construction.

SUITABILITY CODES

- A- These soils should have the capacity to function as suitable media for a conventional septic system absorption field provided the system is properly designed, installed and maintained.
- D- Due to flooding potential or other drainage problems, these areas are unsuitable for septic system construction.

**Legend**

- Hand auger boring
- Slope direction
- ▨ Fill
- Ephemeral draw

SOIL INVESTIGATION - LEVEL THREE

BURNETT ENVIRONMENTAL CONSULTING, LLC  
 160 STEEPVIEW DRIVE  
 ATHENS, GA 30606  
 CELL: 770-337-2959  
 EMAIL - DBURNETT76@GMAIL.COM

SCALE: 1" = 50 FT.

LOT 39 - SHORES AT LYNCLIFF COVE  
 L.L. 68 DISTRICT 10  
 HALL COUNTY, GEORGIA  
 FOR: MCKINLEY HOMES

SHEET  
 1 OF 1